



Fire Test Certificate

This is to certify that the specimen described below has been examined by BRANZ Ltd on behalf of

EPS Panel Division, PACIA
and
CSIRO Manufacturing and Infrastructure Technology

Test standard: AS ISO 9705

Specimen name: Sandwich Panel with an Expanded Polystyrene (EPS) core

Specimen description:

Insulating sandwich panel, with nominal thickness 150 mm or less.

Panel core of Class S or SL (to AS 1366.3) expanded EPS.

Clad both sides with "Colorbond" steel, thickness 0.4 mm or greater.

Panel to panel corner junctions require aluminium angles fixed to the steel skins at not more than 300mm centres, with aluminium rivets.

Orientation: N/A

Full descriptions of the test specimen and the complete results of the examination are given in the following Test Reports and Assessments:

CMIT-(c)-2003-201 CMIT-(c)-2004-089 CMIT-(c)-2004-368 CMIT-(c)-2004-469
BRANZ FAR 2489

Conditions of laboratory registration by IANZ do not allow assessments expressed by the Registered Laboratory to be covered by IANZ.

Regulatory authorities are advised to examine test reports and assessments before approving any product.

The assessed results were as follows:

Group Number 2 in accordance with BCA 2005 specification Cl.10a

Smoke Growth Rate Index (SMOGR_{RC}) < 100.

Test Dates: 15/9/03, 23/1/04, 6/2/04, 6/9/04
22/9/04, 24/11/04, 6/12/04

Test Supervisor(s): N/A

This Certificate issued:

Certificate Number: 373

29 April 2005

Colleen Wade, Principal Scientist

*Fire Testing Supervisor
For BRANZ Limited*